

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161581, Building Permit - Commercial
Address: 600 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Passed	Tuesday, October 11, 2016
Final Plumbing Inspection - Commercial	John Borns	Passed	Tuesday, October 11, 2016

Comments: PRESSURE TEST @ 110 PSI PERFORMED ON 4" GAS FEEDER LINE FROM NEAR O'BRIEN TO ~120' NW. CLOSE PERMIT.