

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162494, Building Permit - Commercial  
Address: 521 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Tuesday, October 18, 2016

Partial Correction

1 Misc 1

OK TO POUR WHEN READY CONCRETE LIGHT POLE BASE(S) AT FOLLOWING LOCATIONS: #2; #3; #5; **#1; #4; #6; #7**

Partial Correction

2 Misc 1

GROUND RODS FOUND DRIVEN IN PLACE: G.E.C. CAD-WELDED AT L.P. LOCATIONS #2; #3; #5. **LISTED CLAMPS AT #1; #4; #6; #7**

Partial Correction

3 Misc 1

OK TO COVER WHEN READY BURIED CONDUIT FOR SITE LIGHTING INTERCONNECTING L.P. LOCATIONS #1 THRU #7

**Comments:**