

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162211, Building Permit - Commercial
Address: 410D SE 3RD ST, Unit:105, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Passed	Tuesday, October 18, 2016

Comments: ONE DOUBLE MC BOX CONNECTOR TO BE REPLACED WITH SINGLE. OK TO COVER WHEN READY.