

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162211, Building Permit - Commercial
Address: 410D SE 3RD ST, Unit:105, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	John Borns	Not Ready	Friday, October 21, 2016

Corrective Action Required

1	Misc 1	LSCO 7-608: GAS PIPING NOT PRESSURED-UP FOR TEST
---	--------	--

Comments: