

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162211, Building Permit - Commercial  
Address: 410D SE 3RD ST, Unit:105, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:   | Inspector: | Outcome:  | Date:                    |
|---|------------|-----------|--------------------------|
| <b>Gas Service Inspection - John Borns<br/>Commercial</b> |            | Not Ready | Friday, October 21, 2016 |

Corrective Action Required

|   |        |  |
|---|--------|--|
| 1 | Misc 1 | LSCO 7-608: GAS PIPING NOT PRESSURED-UP FOR TEST |
|---|--------|--|

|   |        |                          |
|---|--------|--------------------------|
| <b>Gas Service Inspection - John Borns<br/>Commercial</b> | Passed | Friday, October 21, 2016 |
|---|--------|--------------------------|

**Comments: RELEASE GAS SERVICE**