

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162097, Building Permit - Commercial  
Address: 1184 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Failed	Wednesday, October 26, 2016

Corrective Action Required

1 Misc 1

COMPLETE REMOVAL OF ABANDONED HANGERS / BRACES

Corrective Action Required

2 Misc 1

ELIMINATE UNUSED OPENINGS AND CONNECTORS AT ELECTRICAL J.B.'s

Corrective Action Required

3 Misc 1

SECURE MC CABLE WITHIN 12" OF ENTRY TO J.B.'s EXCEPT FIXTURE WHIPS NO MORE THAN 6' LONG.  
SUPPORT MC CABLE AT MAX 6' INTERVALS.

**Comments:**