

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160414, Building Permit - Commercial  
Address: 1440 SE BROADWAY DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mike Copeland	Partial	Friday, October 28, 2016

Partial Correction  
1 Misc 1

-ELECTRICAL IN WALL ONLY AND FRAMING APPROVED.

ATTACH TOP PLATE WEST ELEVATION TO WOOD FRAMING,  
WELDED BRACKET NOT CONNECTED TO FRAMING.

ABOVE CEILING NOT READY FOR INSPECTION.

<b>Above Ceiling Inspection</b>	Mike Copeland	Not Ready	Friday, October 28, 2016
---------------------------------	---------------	-----------	--------------------------

**Comments:**