



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

October 28, 2016

BUMGARNER ASSOCIATES
4210 SW CLIPPER CIR
LEES SUMMIT, MO 64082

Permit No: PRCOM20162806
Project Title: MEDIQUICK AESTHETICS
Project Address: 100 SW 3RD ST, Unit:B, LEES SUMMIT, MO 64063
Parcel Number: 61340231300000000
Location: LEES SUMMIT TOWN OF ALL OF THE E 90' OF LOTS 1 & 2 BLK 11
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: TENANT FINISH FOR SKIN CARE CLINIC

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Jim Eden

Approved with Conditions

2. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

POST THE SUITE ADDRESS ON THE EXTERIOR OF THE FRONT AND REAR DOORS IN A CONTRASTING COLOR TO THE BACKGROUND. THE FRONT ADDRESS SHALL BE READABLE FROM THE ROADWAY (3RD STREET) (VERIFIED AT INSPECTION)

3. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

PROVIDE ONE 2A-10BC FIRE EXTINGUISHER (RATED 5 POUND)
(VERIFIED AT INSPECTION)

4. 2012 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be

along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

MOUNT THE FIRE EXTINGUISHER ON A NORMAL PATH OF TRAVEL CLOSE TO AN EXIT
(VERIFIED AT INSPECTION)

5. PLANS ARE SHOWING SMOKE DETECTION TO BE INSTALLED. SMOKE DETECTION IS NOT REQUIRED. (INFORMATION PURPOSES)

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.