

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20162248, Building Permit - Residential
Address: 1353 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Suspended Slab Inspection	Khanh Nguyen	Failed	Friday, October 28, 2016

Corrective Action Required

1	Misc 1	-HAVE ENGINEER ADDRESS THE REAR I BEAM SUPPORT OF SLAB NOT PER PLAN
---	--------	--

Comments: