

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162494, Building Permit - Commercial
Address: 521 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Monday, October 31, 2016
Partial Correction 1 Misc 1		OK TO POUR WHEN READY CONCRETE LIGHT POLE BASE(S) AT FOLLOWING LOCATIONS: #2; #3; #5; #1; #4; #6; #7; #9; #10; #11; #8; #12; #13;	
Partial Correction 2 Misc 1		GROUND RODS FOUND DRIVEN IN PLACE: G.E.C. CAD-WELDED AT L.P. LOCATIONS #2; #3; #5. LISTED CLAMPS AT #1; #4; #6; #7;	
Partial Correction 3 Misc 1		OK TO COVER WHEN READY BURIED CONDUIT FOR SITE LIGHTING INTERCONNECTING L.P. LOCATIONS #1 THRU #7; #9 TO #10; #11 TO #12 TO #13; #8 TO #9; #10 TO #11;	
Underground Electrical Inspection - Commercial	John Borns	Partial	Monday, October 31, 2016
Partial Correction 1 Misc 1		OK TO COVER WHEN READY BURIED CONDUIT FOR SITE LIGHTING INTERCONNECTING L.P. LOCATIONS #1 THRU #7; #9 TO #10; #11 TO #12 TO #13;	
Partial Correction 2 Misc 1		GROUND RODS FOUND DRIVEN IN PLACE: G.E.C. CAD-WELDED AT L.P. LOCATIONS #2; #3; #5. LISTED CLAMPS AT #1; #4; #6; #7;	
Partial Correction 3 Misc 1		OK TO POUR WHEN READY CONCRETE LIGHT POLE BASE(S) AT FOLLOWING LOCATIONS: #2; #3; #5; #1; #4; #6; #7; #9; #10; #11;	

#8; #12; #13;

Comments: