

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161181, Building Permit - Commercial  
Address: 521 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|   |            |          |                          |
|---|------------|----------|--------------------------|
| Inspection:   | Inspector: | Outcome: | Date:                    |
| <b>Underslab Plumbing<br/>Inspection -<br/>Commercial</b> | John Borns | Passed   | Monday, October 31, 2016 |

**Comments: OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING  
AT: NW OF BLDG DRAIN UNDER CORRIDOR AND SW OF BLDG DRAIN TO EXTERIOR AT UNIT [B114];  
UNITS B108 & B109 @ SW QUADRANT; REMAINDER OF BUILDING AREA AT NE**

**NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.**