

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152438, Building Permit - Commercial  
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Tuesday, November 01, 2016

Partial Correction  
1 Misc 1

CONDUITS BETWEEN LIGHT POLE BASES AT THE FOLLOWING: 11 THROUGH 5.; 100 FEET OF CONDUIT EAST OF POLE 6 FOR HOME RUNS AND FUTURE PHASE POLE BASE; 1 TO 2 TO 4 TO 5; 12 TO 11 + ~30' STUBS FROM EACH TO WEST FOR FUTURE; #11 TO #12 TO #13 TO #14 TO #15 REPAIR OF DAMAGED STORM SEWER LINE IN PROGRESS 45' NORTH OF #14; **#15 TO #16 TO #17;**

**Comments:**