

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161426, Building Permit - Commercial
Address: 720 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Passed	Tuesday, November 01, 2016

Underslab Electrical Inspection - Commercial	John Borns	Partial	Tuesday, November 01, 2016
---	------------	---------	----------------------------

Partial Correction
1 Misc 1

NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT MATERIAL & WORKMANSHIP. G.C. AND E.C. TO ENSURE LAYOUT IS CORRECT. OK TO COVER WHEN READY EXCEPT EAST 50';

Comments: OK TO COVER WHEN READY FOUR 8" PVC ROOF DRAIN SWEEPS THROUGH SOUTH WALL(2) OR UNDER FOOTING(2).