

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161181, Building Permit - Commercial
Address: 521 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Passed	Wednesday, November 02, 2016

Comments: NO ISSUES FOUND ON MATERIAL AND WORKMANSHIP FOR INSTALLATION OF UNDER-SLAB ELECTRICAL CONDUIT, INCLUDING FOUR 3" PVC CONDUITS AT ELECTRICAL ROOM. UFER GROUND G.E.C. RUN FROM GRADE BEAM ENTRY TO ELECTRICAL ROOM.