

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Wednesday, November 02, 2016

Partial Correction
1 Misc 1

OK TO COVER WHEN READY NORTH & SOUTH EXTERIOR WALLS AT UNITS ONLY AT 4TH, 3RD, AND 2ND FLOORS AFTER...

- PATCH HOLE IN EXTERIOR SHEATHING AT 2ND FLOOR UNIT POINTED OUT**
- FIRE-BLOCK TEMP CONTROL BORES OF PLATES**

Comments: