

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20152455, Building Permit - Commercial
Address: 820 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Thursday, November 03, 2016

Partial Correction

1 Misc 1

OK TO COVER WHEN READY SECTIONS OF LIGHT-GAUGE STEEL
ELEVATED WALL FRAMING AT:
ON (B) FROM (3) TO (4) AND (6) TO (7)
ON (1) FROM (B) TO (C)
ON (C) FROM (1) TO (3)
ON (3) FROM (C) TO (E)

Corrective Action Required

2 Misc 1

SOFFIT FRAMING PER DETAIL C4/A413 AT (A) FROM (2) TO (7):
SCREW BOTH FLANGES AT OUTLOOKER CONNECTIONS TO
HEADER TRACK MEMBER

Comments: