



**WILLIAM E. MANZ, P. E.
STRUCTURAL ENGINEER
6328 HIGHLAND ESTATES DR.
ST. LOUIS, MO. 63129**



COLS. 1 & PG REQ. REINFMNT
OTHER 6 COLS DO NOT.

AS NOTED ON PLANS REVIEW
CODES ADMINISTRATION
LEE'S SUMMIT, MISSOURI

15

DATE _____

10/28/16

MEZZ. PLAN

P1-19.3^k
P6-17.3^k

TYP
FLD. WELD.

EXIST'G 6x6 COL
E 12x12x $\frac{3}{4}$ BASE PL

Plan

NEW $1\frac{1}{2} \times \frac{3}{4}$ - 4 SIDES
w/ $3" \times \frac{1}{2}$ STIFF BAR

ONLY
CONS-PIE PG

3'-1-0 BASE PLATE ENLARGEMENT SECTION

Topic: BASE PLATE ENLARGMENT Project: 2724 NE INDEPENDENCE
PERMIT ¹⁰ PRCOM20161204 Project No: LEE SUMMIT, MO. 64064
 By: WFM Date: 10-26-16 Page: 1 OF 2