

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152517, Building Permit - Commercial
Address: 312 NE M 291 HWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Monday, November 07, 2016

Corrective Action Required

1	Misc 1	ADDRESS LABELING OF ELECTRICAL SERVICE METER/DISCONNECT: APPLY PERMANENT ADDRESS STICKER
---	--------	---

Corrective Action Required

2	Misc 1	WIRING AT "BAR" AND POINT OF SERVICE COUNTER IS ENTIRELY NON-CONFORMING. REQUIRES REPLACEMENT BY LICENSED ELECTRICIAN.
---	--------	--

Corrective Action Required

3	Misc 1	REMOVE ABANDONED CABLE CONNECTOR AT ELECTRICAL PANEL AND CLOSE HOLE WITH LISTED PLUG.
---	--------	--

Corrective Action Required

4	Misc 1	RESOLVE FIRE DEPARTMENT ISSUES.
---	--------	---------------------------------

**Comments: IMMEDIATE CORRECTIONS TO WIRING REQUIRED FOR STORE TO CONTINUE OPERATING.
RESTROOM DOES NOT CONFORM TO ICC ACCESSIBILITY REQUIREMENTS, BUT IS NOT REQUIRED TO BE
CONFORMING AT THIS TIME.**