

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20152438, Building Permit - Commercial
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Monday, November 07, 2016

Partial Correction
1 Misc 1

CONDUITS BETWEEN LIGHT POLE BASES AT THE FOLLOWING: 11 THROUGH 5.; 100 FEET OF CONDUIT EAST OF POLE 6 FOR HOME RUNS AND FUTURE PHASE POLE BASE; 1 TO 2 TO 4 TO 5; 12 TO 11 + ~30' STUBS FROM EACH TO WEST FOR FUTURE; #11 TO #12 TO #13 TO #14 TO #15; #15 TO #16 TO #17; #17 TO 50' EAST FOR FUTURE; #16 WEST TO BLDG; #4 TO #3 TO #18; FROM #1 TO (A) & TO (B); **COMPLETION OF FROM #6 TO BLDG W WALL; FROM #7 TO BLDG W WALL**

Comments: