

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, November 10, 2016

Partial Correction
1 Misc 1

OK TO COVER WHEN READY COMPONENTS OF RATED CORRIDOR CEILING ASSEMBLY AT: 3RD FLOOR 1ST LAYER; 2ND FLOOR 1ST LAYER; **1ST FLOOR 1ST LAYER;**

Partial Correction
2 Misc 1

OK TO COVER WHEN READY COMPONENTS OF RATED WALL ASSEMBLY AT: SPACE 316 WEST WALL ONE LAYER OK TO TAPE, MUD, AND FIRE-STOP;

Comments: