

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20152455, Building Permit - Commercial
Address: 820 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Friday, November 11, 2016
Partial Correction 1 Misc 1		6" PVC ROOF DRAIN PIPE TOBE CAST INTO BUILDING GRADE BEAM/FOOTING AT	
Partial Correction 2 Misc 1		4" SANITARY BUILDING SEWER FROM BUILDING ENTRY TO EAST 35';	
Partial Correction 3 Misc 1		OK TO COVER WHEN READY 4" PVC UNDER SLAB SANITARY DRAIN, WASTE, & VENT PIPING ON (B.25) FROM (7.1) TO (9) + BRANCH TO FD-1 AT LANDLORD'S RM	
		NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM	
Footing Inspection - Commercial	John Borns	Not Ready	Friday, November 11, 2016

Comments: