

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20152455, Building Permit - Commercial
Address: 820 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|------------------------------------------------------|------------|----------|---------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Rough Framing Inspection - Commercial | John Borns | Partial | Friday, November 11, 2016 |

Partial Correction
1 Misc 1

OK TO COVER WHEN READY SECTIONS OF
LIGHT-GAUGE STEEL HIGH/ELEVATED WALL
FRAMING AT:
ON (B) FROM (3) TO (4) AND (6) TO (7)
ON (1) FROM (B) TO (C)
ON (C) FROM (1) TO (3)
ON (3) FROM (C) TO (E)
ON (1) FROM (C) TO (D)
ON (E) FROM (2) TO (3)
ON (A) FROM (1) TO (2)
ON (1) FROM (A) TO (A.4)
SOFFIT BOX-OUT ON (1) FROM (C.1) TO (C.9)

Partial Correction
2 Misc 1

EXTERIOR EAVE SOFFIT FRAMING OK AT COVER AT: EAST WALL;

| | | | |
|--------------------------------------------|------------|-----------|---------------------------|
| Footing Inspection - Commercial | John Borns | Not Ready | Friday, November 11, 2016 |
|--------------------------------------------|------------|-----------|---------------------------|

Partial Correction
1 Misc 1

PHASE II: AFTER TRENCH IS CLEANED FOR RE-BAR COVERAGE AT
NE CORNER OK TO POUR WHEN READY PERIMETER GRADE BEAM
& INTEGRAL COLUMN FOOTINGS + ISOLATED FOOTING C.2/8

FOOTING C.2/7.1 NOT READY

**Underslab Plumbing
Inspection -
Commercial**

John Borns

Partial

Friday, November 11, 2016

Partial Correction

1 Misc 1

6" PVC ROOF DRAIN PIPE TOBE CAST INTO BUILDING GRADE
BEAM/FOOTING AT

Partial Correction

2 Misc 1

4" SANITARY BUILDING SEWER FROM BUILDING ENTRY TO EAST
35';

Partial Correction

3 Misc 1

OK TO COVER WHEN READY 4" PVC UNDER SLAB SANITARY
DRAIN, WASTE, & VENT PIPING ON (B.25) FROM (7.1) TO (9) +
BRANCH TO FD-1 AT LANDLORD'S RM

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR
PRESSURE-TESTING PIPING SYSTEM

Comments: