

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152455, Building Permit - Commercial
Address: 820 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	John Borns	Partial	Tuesday, November 15, 2016

Partial Correction
1 Misc 1

MC ELECTRICAL CABLE AND METALLIC FLEX CONDUIT EXTENDED FROM INSIDE CMU WALL THROUGH PLYWOOD SHEATHING AT NE CORNER OF BLDG;

Comments: