

Temporary Certificate of Occupancy

Permit #: PRCOM20162097
Address: 1184 NE DOUGLAS ST, LEES SUMMIT, MO 64086
Inspected On: Tuesday, November 15, 2016
Inspected By: John Borns
Expiration Date: 12/1/2016 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Tuesday, November 15, 2016

Corrective Action Required:

1 Misc 1 RESOLVE FIRE DEPT ISSUES

NEC 600.4 ELECTRIC SIGN MARKINGS: SIGNS AND OUTSIDE LIGHTING SYSTEMS SHALL BE SHOP-LABELED WITH LISTING, MANUFACTURER'S NAME, TRADEMARK, OR OTHER MEANS OF IDENTIFICATION; AND INPUT VOLTAGE AND CURRENT RATING.