

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162803, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	John Borns	Passed	Tuesday, November 15, 2016

Footing Inspection - Commercial	John Borns	Partial	Tuesday, November 15, 2016
--	------------	---------	----------------------------

Partial Correction
1 Misc 1

OK TO POUR WHEN READY SECTIONS OF CONCRETE GRADE BEAM + INTEGRAL COLUMN FOOTINGS AS MARKED ON PERMIT PRINTS: POINTS (A) THRU (M); (M) C/W TO (N); (U) TO (V); **(U) TO (T) TO (S) TO (R) TO (Q); (A) TO (W);**

Comments: UFER GROUND JUMPER CONNECTED TO GRADE BEAM LONGITUDINAL RE-BAR AT GRADE BEAM POUR POINT (A)