

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Failed	Tuesday, November 15, 2016

Corrective Action Required
1 Misc 1

4TH FLOOR WALLS AND CEILINGS: **FIRE-BLOCK TOPS OF ALL CHASES / DEAD SPACES**

ELEVATOR SHAFT NOT READY FOR INSPECTION

Comments: