

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162474, Building Permit - Commercial
Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Failed	Wednesday, November 16, 2016
Partial Correction 1 Misc 1		THREE FOOTINGS AT 30"x30" + ONE AT 16"x16" PREPARED FOR POUR. ONE ADDITIONAL AT 16"x16" TO BE SHOWN ON REVISED DRAWING NOT READY FOR INSPECTION.	
Corrective Action Required 2 Misc 1		FOUR PIERS AT WEST END OF BUILDING FOUND TO HAVE 0" (NW PIER DOES NOT EXTEND BELOW GRADE) TO 18" DEPTH BELOW GRADE. NOT APPROVED TO SUPPORT ANTICIPATED DEAD AND LIVE LOADS. LICENSED A/E REPORT REQUIRED.	

Comments: