
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20161619, Public Works Infrastructure Permit - Commercial

The Summit Church (NW Ashurst Dr. & NW Edgewood Dr.) Sanitary Sewer (offsite)

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|-------------------|-----------------|------------------------------------|
| PW-Sanitary Sewer - Vacuum | Steve Robbins | Partial | Wednesday, November 16, 2016 |

Informational

- 1 MH 1-1 has been installed and we did a vacuum test so they can get this backfilled and tested and get the road back open. It passed the test 2.5 minutes. We will continue with the others after they are installed. Steve Robbins 11/16/2016 2:14 PM

Comments:
