

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162803, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Wednesday, November 16, 2016
Partial Correction 1 Misc 1		OK TO POUR WHEN READY SECTIONS OF CONCRETE GRADE BEAM + INTEGRAL COLUMN FOOTINGS AS MARKED ON PERMIT PRINTS: POINTS (A) THRU (M); (M) C/W TO (N); (U) TO (V); (U) TO (T) TO (S) TO (R) TO (Q); (A) TO (W); (O) C/W TO (Q); (V) TO (V')	
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, November 16, 2016
Partial Correction 1 Misc 1		OK TO COVER WHEN READY BURIED CONDUIT FOR SITE ELECTRICAL SYSTEM AT FOLLOWING LOCATIONS NUMBERED ON SITE PLAN IN PERMIT PRINT SET: #1 TO #2;	

Comments: