

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152438, Building Permit - Commercial  
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	John Borns	Partial	Thursday, November 17, 2016

Corrective Action Required

1	Misc 1	WEATHER-EXPOSED STEEL PIPE MUST BE PAINTED AS CORROSION PROTECTION.
---	--------	---

Corrective Action Required

2	Misc 1	ENSURE SUPPORT BLOCKS LOCATED AT/NEAR TEES AND 90'S AT ROOFTOP PIPING
---	--------	---

<b>Gas Service Inspection - Commercial</b>	John Borns	Passed	Thursday, November 17, 2016
--	------------	--------	-----------------------------

<b>In-wall Inspection</b>	John Borns	Partial	Thursday, November 17, 2016
---------------------------	------------	---------	-----------------------------

Partial Correction

1	Misc 1	OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING LOCATIONS: ONE-SIDING OF: - ELECT [115] - VEST [118] N WALL TWO LAYERS S FACE - TWO 4' WIDE STACKS @ PLATFORM [117] FOR DUCTWORK - MECH [145] **BOCA PLATES MISSING**
---	--------	---

**Comments: GAS SERVICE RELEASED TO MGE.**