

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162829, Building Permit - Commercial
Address: 401 NE COLBERN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Underground Electrical John Borns
Inspection -
Commercial

Partial

Thursday, November 17, 2016

Partial Correction

1 Misc 1

OK TO POUR WHEN READY LIGHT POLE BASES AT FOLLOWING
LOCATIONS NUMBERED ON SITE PLAN IN PERMIT PRINT SET: #1
THRU #11; **#13; #15; #16; #18; #20; #21 THRU #25;**

Partial Correction

2 Misc 1

OK TO COVER WHEN READY TRENCHED CONDUIT AT FOLLOWING
LIGHT POLE LOCATIONS NUMBERED ON SITE PLAN IN PERMIT

PRINT SET: Q-BOX TO #14; #13 TO #14 TO #15 TO #16; #15 TO #20; #20 TO #21;

AT ENTRANCE DRIVE OK TO DIG, LAY CONDUIT AND COVER
WHEN READY WITHOUT INSPECTION

Comments: