

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160414, Building Permit - Commercial  
Address: 1440 SE BROADWAY DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Passed	Thursday, November 17, 2016

**Comments: IN-WALL ROUGH-IN ONLY (NOT ABOVE-CEILING) OK TO COVER WHEN READY AFTER...**  
**- ONE CUT-OFF STUD IS EXTENDED TO BOTTOM PLATE**  
**- ALL STUD SHOES ARE FULLY NAILED PER MANUFACTURER'S INSTRUCTIONS**