

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160939, Building Permit - Commercial
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Monday, November 21, 2016

Partial Correction
1 Misc 1

UNDERGROUND ELECTRICAL OK BELOW:
-~20 FT OF RACEWAY FOR EXTERIOR LIGHT NORTH OF BUILDING
-SECONDARY DEOM TRANSFORMER TO BUILDING

Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Partial	Monday, November 21, 2016
---	--------------	---------	---------------------------

Partial Correction
1 Misc 1

UNDERSLAB PLUMBING OK BELOW:
-ZONE A: OK EXCEPT THERAPY RM

Comments: