

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20160041, Public Works Infrastructure Permit - Commercial
Holiday Inn Express (1201 NW Innovation Pkwy.)FDP
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Commercial Curb Inspection	Steve Robbins	Partial	Monday, November 21, 2016

Informational

1 Today they are foming up curbs for the parking lot.Steve Robbins 11/10/2016 11:46 AM

Informational

2 Some of the curbs have been poured on the north side of the parking lot and today they are pouring some of the parking lot on the south side also.Steve Robbins 11/14/2016 12:05 PM

Informational

3 Today they are putting in concrete for the parking lot on the west side of the building. They still need to finish the curbs , but they are doing it as they go.Steve Robbins 11/21/2016 3:51 PM

Comments: