

---

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

---

Permit #: PRPWFC20161633, Public Works Infrastructure Permit - Commercial  
Lee's Summit Honda Parking Addition (301 NE Colbern Rd)  
Address: 301 NE COLBERN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Curb - Proof Roll	Steve Robbins	Passed	Monday, November 21, 2016

Informational

- 1 Today we did a proof roll on the parking lot, The proof roll passed and the compaction tests were taken and they will give thosed to me later.Steve Robbins 11/21/2016 3:57 PM

Informational

- 1 Proof roll for the curb was done on 11/1/16 . Still need one for the parking lot.Steve Robbins 11/16/2016 2:22 PM

Informational

- 2 Today they are doing grading and they did a stringline to make sure they have at least 7' dept as per the plans. They still need a proofroll and a compaction test on the parking lot.Steve Robbins 11/21/2016 8:52 AM

PW-Curb - Proof Roll	Steve Robbins	Partial	Monday, November 21, 2016
----------------------	---------------	---------	---------------------------------

Informational

- 1 Proof roll for the curb was done on 11/1/16 . Still need one for the parking lot.Steve Robbins 11/16/2016 2:22 PM

Informational

- 2 Today they are doing grading and they did a stringline to make sure they have at least 7' dept as per the plans. They still need a proofroll and a compaction test on the parking lot.Steve Robbins 11/21/2016 8:52 AM

**Comments:**

---