## PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Inspection Summary**

Permit #:PRCOM20161058, Building Permit - Commercial Address: 1200 SE HAMBLEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

**Footing Inspection -** Mike Copeland Partial Tuesday, November 22, 2016

Commercial

**Partial Correction** 

1 Misc 1 \*\*\*AREA A\*\*\*

-EXTERIOR GRADE BEAM AND COLUMN PADS OK:

FROM LINE 5A/AA TO 14A/CC; F27.8 PAD WITHOUT GRADE

BEAM ON TOP; KK TO 4A; LL LINE; 1A LINE

;AA-JJ

-ISOLATED COLUMN PADS OK:

9A/CC, 9A/HH, CA-HH, JJ; 6A/CC; 6A/JJ; HH/1

HARDENED ROOM APPROVED.

ISOLATED PADS: D.3/17; D.3/15.4; D.3/15 WERE NOT

INSPECTED BY CITY INSPECTIONS. CHECK SPECIAL INSPECTIONS.

GRADE BEAM AND PADS A LINE FROM 10-14 APPROVED.

EAST SIDE OF HARDENED ROOM LINE A APPROVED

**Partial Correction** 

2 Misc 1 \*\*\*AREA B\*\*\*\*

ISOLATED PADS: B.5/13; B.5/11; E.3/12; E.3/13; E.3/15; D.3/12;

A/11; A/13

NORTH GRADE BEAM AND PADS: E7 LINE B.5

**Partial Correction** 

3 Misc 1 \*\*\*AREA A\*\*\*

-EXTERIOR GRADE BEAM AND COLUMN PADS OK:

FROM LINE 5A/AA TO 14A/CC; F27.8 PAD WITHOUT GRADE

BEAM ON TOP; KK TO 4A; LL LINE; 1A LINE

;AA-JJ

-ISOLATED COLUMN PADS OK:

9A/CC, 9A/HH, CA-HH,JJ; 6A/CC; 6A/JJ; HH/1

HARDENED ROOM APPROVED.

ISOLATED PADS: D.3/17; D.3/15.4; D.3/15 WERE NOT

INSPECTED BY CITY INSPECTIONS. CHECK SPECIAL INSPECTIONS.

GRADE BEAM AND PADS A LINE FROM 10-14 APPROVED.

**Partial Correction** 

4 Misc 1 \*\*\*AREA B\*\*\*\*

ISOLATED PADS: B.5/13; B.5/11; E.3/12; E.3/13; E.3/15; D.3/12;

A/11; A/13

NORTH GRADE BEAM AND PADS: E7 LINE B.5

**Partial Correction** 

5 Misc 1 AREA D AND C

FOOTINGS BETWEEN 9 AND 11 LINES APPROVED, LOCKER

**ROOMS APPROVED** 

BOILER ROOM FOOTING APPROVED

**Comments:**