

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20161633, Public Works Infrastructure Permit - Commercial  
Lee's Summit Honda Parking Addition (301 NE Colbern Rd)  
Address: 301 NE COLBERN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

**Inspection Item:**

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
PW-Proof roll parking lot	Steve Robbins	Passed	Tuesday, November 22, 2016

**Informational**

1 Proofroll has been completed and passed Steve Robbins 11/22/2016 11:44 AM

PW-Street - Base Lift	Steve Robbins	Partial	Tuesday, November 22, 2016
-----------------------	---------------	---------	----------------------------------

**Informational**

1 Today 5" of base was put down for about 1/3 of the parking lot , it started to rain so they have stopped for the day. This parking lot is getting 7" of asphalt on dirt per the plans, they were initiated in 2015, I talked to Gene and Kent and it has been approved. Steve Robbins 11/22/2016 11:51 AM

**Comments:**