

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20152714, Building Permit - Residential
Address: 249 SE COYLE DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Failed	Tuesday, November 22, 2016

Corrective Action Required

1	Misc 1	OBTAIN IRRIGATION PERMIT
		INSTALL BACKFLOW DEVICE AT BASEMENT HOSE BIBB.

Comments: