

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20152438, Building Permit - Commercial
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Wednesday, November 23, 2016
Partial Correction 1 Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING LOCATIONS: ONE-SIDING OF: - ELECT [115] - VEST [118] N WALL TWO LAYERS S FACE - TWO 4' WIDE STACKS @ PLATFORM [117] FOR DUCTWORK - MECH [145] **BOCA PLATES MISSING** - SOUTH WALL OF E-W LEG OF N END OF CORR [128];	

Comments: