

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161080,  
Address: 521 SE 2ND ST, Unit:B, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Fire</b>	Joe Dir	Not Ready	Wednesday, November 23, 2016

<b>Final Building Inspection - Commercial</b>	John Borns	Partial	Wednesday, November 23, 2016
---	------------	---------	------------------------------

Corrective Action Required

6 Misc 1

POWER NOT INSTALLED FOR TV'S AT PATIENT CHAIRS

Corrective Action Required

9 Misc 1

PEX TUBING AT MECHANICAL ROOM NOT APPROVED -- POINTED OUT TO G.C.

Partial Correction

10 Misc 1

**OK FOR USE AND OCCUPANCY THROUGH 12/8/16 WITHIN WHICH TIME REMAINING ISSUES ARE TO BE CORRECTED.**

**Comments:**