

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152455, Building Permit - Commercial  
Address: 820 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Partial	Wednesday, November 23, 2016

Partial Correction

1          Misc 1

OK TO COVER WHEN READY SECTIONS OF LIGHT-GAUGE STEEL  
HIGH/ELEVATED WALL FRAMING AT:  
ON (B) FROM (3) TO (4) AND (6) TO (7)  
ON (1) FROM (B) TO (C)  
ON (C) FROM (1) TO (3)  
ON (3) FROM (C) TO (E)  
ON (1) FROM (C) TO (D)  
ON (E) FROM (2) TO (3)  
ON (A) FROM (1) TO (2)  
ON (1) FROM (A) TO (A.4)  
SOFFIT BOX-OUT ON (1) FROM (C.1) TO (C.9)  
ON (E) FROM (2) TO (3)  
COLUMN BOX-OUTS ON (E) AT (3), (4.5) & (5.9)\*\*  
**TALL & ELEVATED FRAMING @ NW CORNER**

**\*\*CROSS-BRACING TO BE INSTALLED AT 8' & 16" AFF**

Partial Correction

2          Misc 1

EXTERIOR EAVE SOFFIT FRAMING OK AT COVER AT: EAST WALL;

**Comments:**