

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152438, Building Permit - Commercial
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Tuesday, November 29, 2016

Partial Correction
1 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING
+ IN-WALL SYSTEMS AT FOLLOWING LOCATIONS:
ONE-SIDING OF:
- ELECT [115]
- VEST [118] N WALL TWO LAYERS S FACE
- TWO 4' WIDE STACKS @ PLATFORM [117] FOR DUCTWORK
- MECH [145] **BOCA PLATES MISSING**
- SOUTH WALL OF E-W LEG OF N END OF CORR [128]; [131]-[143];
[145]; [147]-[150]; [157];

Comments: