

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20151897, Building Permit - Commercial  
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Tuesday, November 29, 2016

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY COMPONENTS OF RATED CORRIDOR CEILING ASSEMBLY AT: 3RD FLOOR 1ST LAYER; 2ND FLOOR 1ST LAYER; 1ST FLOOR 1ST LAYER INCLUDING AT PVC PLUMBING PIPING AT WEST END;

Partial Correction  
2 Misc 1

OK TO COVER WHEN READY COMPONENTS OF RATED WALL ASSEMBLY AT: OK TO TAPE, MUD, AND FIRE-STOP ONE LAYER 5/8" TYPE C GWB PRE-ROCK FOR ELECTRICAL PANELS AT SPACES 316; 216;

ENSURE MAX 1/8" MARGINS AT ELECT BOX CUT-OUTS.

Partial Correction  
3 Misc 1

**RESILIENT CHANNEL PER UL U522 OK TO COVER WHEN READY AT WALLS AND CEILINGS AT: 4TH FLOOR EXCEPT AT STAIRWELLS AND ROOMS 430 AND 432;**

**Comments:**