



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20162583

Date: December 01, 2016

Project Title: SAINT LUKES HOSPITAL - CATH LAB EXPANSION

Applicant:

Location:

20 NE SAINT LUKES BLVD, LEES
SUMMIT, MO 64086

JAYHAWK FIRE SPRINKLER CO INC
PO BOX 8458
TOPEKA, KS 66608

Type of Work:

Primary: (913) 422-3770

Occupancy Group: I-2

Description: CATH LAB EXPANSION

Construction Type: Type IA

Map Page: 175X

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

EXISTING SPSRINKLER SYSTEM RISERS SHALL BE CURRENT WITH ALL REQUIRED SERVICE/MAINTENANCE. A CURRENT SERVICE TAG SHALL BE POSTED ON THE RISERS.
(VERIFIED AT INSPECTION)

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.