

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20160499, Public Works Infrastructure Permit - Commercial  
Hangar T

Address: 2751 NE DOUGLAS ST, Unit:T, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Hydrant Inspection	Steve Robbins	Partial	Friday, December 02, 2016

Informational

- 1 The fire hydrant on this property which was already there is not at the correct height. I talked to the contractor and he did not want to make it right. I then talked to Kent and it was determined he had to fix it, I called him today and I left him a message telling him he had to fix it. Steve Robbins 12/02/2016 12:59 PM

Comments: