

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20151897, Building Permit - Commercial  
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Partial	Monday, December 05, 2016

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY WALLS AND CEILINGS AT: 4TH FLOOR; 3RD FLOOR AFTER SRINKLER PIPE IS PROTECTED WITH BOCA PLATES AT PENETRATIONS OF TOP WALL PLATES; **116 E&S WALLS;**

ELEVATOR SHAFT AND STAIRWELLS NOT READY FOR INSPECTION

**Comments:**