

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161080,
Address: 521 SE 2ND ST, Unit:B, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Failed	Tuesday, December 06, 2016

Corrective Action Required

1 Misc 1

**ELECTRICAL WIRING AND BOXES TO POWER TV'S AT PATIENT
CHAIRS NOT EXPOSED FOR INSPECTION. ELECTRICAL
CONTRACTOR TO MAKE ARRANGEMENTS WITH INSPECTOR TO
INSPECT ABOVE CEILING.**

Comments: