

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20163096, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Wednesday, December 07, 2016

Corrective Action Required

1 Misc 1

CONDUIT NOT IN PLACE AT SOUTH TRENCH.

Corrective Action Required

2 Misc 1

ENSURE 2" - 3" CONCRETE UNDER CONDUIT IN PAVING AREAS.

**Comments:**