

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Thursday, December 08, 2016
Partial Correction 1 Misc 1		OK TO COVER WHEN READY ONE 3" PVC DATACOMM CONDUIT AT WEST END OF BLDG; INSTALLATION IN PROGRESS OF TWO 3" PVC CONDUITS W>E ACROSS LENGTH OF BLDG;	
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Thursday, December 08, 2016
Partial Correction 1 Misc 1		OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT:FROM WEST END EAST TO 6" BLDG DRAIN + 6" SOUTH TO UNDER FOOTING; REMAINDER OF PVC UNDER-SLAB DWV EXCEPT LINES TO POOL & EMPLOYEE RR;	
		NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.	
Underslab Electrical Inspection - Commercial	John Borns	Partial	Thursday, December 08, 2016
Partial Correction 1 Misc 1		OK TO COVER WHEN READY ONE 3" PVC DATACOMM CONDUIT	

AT WEST END OF BLDG; INSTALLATION IN PROGRESS OF TWO 3"
PVC CONDUITS W>E ACROSS LENGTH OF BLDG;

Comments: