

Inspection Summary

Permit #: PRCOM20161080,
Address: 521 SE 2ND ST, Unit:B, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial		Closed with comment	Thursday, December 08, 2016

**Comments: E.C. TO ENSURE MC ELECTRICAL CABLE FOR TV'S IS PROPERLY SECURED AND SUPPORTED.
CLOSE PERMIT.**